

	Solar	560	0	0	0.09	4	
	Renewable(Total)	848	0	0	0.30	13	
	Total Punjab	8408	596	1747	32.19	1341	
Haryana	Panipat TPS (2*210+2*250)	920	210	209	5.24	218	
	DCRTPP (Yamuna nagar) (2*300)	600	554	449	11.12	463	
	Faridabad GPS (NTPC)(2*137.75+1*156)	432	0	0	0.00	0	
	RGTPP (khedar) (IPP) (2*600)	1200	0	0	0.00	0	
	Magnum Diesel (IPP)	25	0	0	0.00	0	
	Jhajjar(CLP) (2*660)	1320	0	0	0.00	0	
	Thermal (Total)	4497	764	658	16.36	682	
	Total Hydro	62	24	29	0.60	25	
	Wind Power	0	0	0	0.00	0	
	Biomass	40	0	0	0.00	0	
	Solar	0	0	0	0.00	0	
	Renewable(Total)	40	0	0	0.00	0	
	Total Haryana	4599	788	687	16.96	707	
	Rajasthan	kota TPS (2*110+2*195+3*210)	1240	322	310	7.69	320
suratgarh TPS (6*250)		1500	189	181	4.72	196	
Chabra TPS (4*250)		1000	667	762	16.20	675	
Chabra TPS (1*660)		660	271	278	6.50	271	
Dholpur GPS (3*110)		330	0	0	0.00	0	
Ramgarh GPS(1*37.5 + 1*35.5 +2*37.5 +1*110 +1*50)		271	190	183	4.87	203	
RAPS A (NPC) (1*100+1*200)		300	190	190	4.24	177	
Barsingsar (NLC) (2*125)		250	226	227	5.16	215	
Giral LTPS (2*125)		250	0	0	0.00	0	
Rajwst LTPS (IPP) (8*135)		1080	752	477	15.83	659	
VS LIGNITE LTPS (IPP) (1*135)		135	0	0	0.00	0	
Kalisindh Thermal(2*600)		1200	520	413	10.92	455	
Kawai(Adani) (2*660)		1320	608	563	13.39	558	
Thermal (Total)		9536	3935	3584	89.51	3730	
Total Hydro		550	20	20	0.49	21	
Wind power		4017	136	110	3.42	143	
Biomass		99	20	20	0.48	20	
Solar		1295	1	0	0.30	12	
Renewable/Others (Total)		5411	157	130	4.20	175	
Total Rajasthan		15497	4112	3734	94.20	3925	
UP		Anpara TPS (3*210+2*500)	1630	1276	1082	24.30	1013
		Obra TPS (2*50+2*94+5*200)	1194	501	491	10.40	433
		Paricha TPS (2*110+2*220+2*250)	1160	827	894	16.40	683
	Panki TPS (2*105)	210	0	135	1.60	67	
	Harduaganj TPS (1*60+1*105+2*250)	665	223	501	7.20	300	
	Tanda TPS (NTPC) (4*110)	440	271	294	5.63	235	
	Roza TPS (IPP) (4*300)	1200	819	1044	18.10	754	
	Anpara-C (IPP) (2*600)	1200	644	618	15.10	629	
	Bajaj Energy Pvt.Ltd(IPP) TPS (10*45)	450	0	281	3.30	138	
	Anpara-D(2*500)	1000	836	825	16.30	679	
	Lalitpur TPS(3*660)	1980	1172	1173	22.00	917	
	Bara(2*660)	1320	52	574	11.40	475	
	Thermal (Total)	12449	6621	7912	151.73	6322	
	Vishnuparyag HPS (IPP)(4*110)	440	108	98	1.80	75	
	Alaknanda(4*82.5)	330	164	84	1.80	75	
	Other Hydro	527	153	99	1.40	58	
	Cogeneration	981	600	600	14.40	600	
	Wind Power	0	0	0	0.00	0	
	Biomass	26	0	0	0.00	0	
	Solar	102	0	0	0.00	0	
	Renewable(Total)	128	0	0	0.00	0	
	Total UP	14855	7646	8793	171.13	7131	
	Uttarakhand	Other Hydro	1250	433	334	8.32	347
Total Gas		225	265	267	5.57	232	
Wind Power		0	0	0	0.00	0	
Biomass		127	0	0	0.00	0	
Solar		20	0	0	0.50	21	
Small Hydro (< 25 MW)		180	0	0	0.00	0	
Renewable(Total)		327	0	0	0.50	21	
Total Uttarakhand		1802	698	601	14.38	599	
Delhi	Raighat TPS (2*67.5)	135	0	0	0.00	0	
	Delhi Gas Turbine (6x30 + 3x34)	282	31	34	0.90	38	
	Pragati Gas Turbine (2x104+ 1x122)	330	151	157	3.74	156	
	Rithala GPS (3*36)	95	0	0	0.00	0	
	Bawana GPS (4*216+2*253)	1370	251	250	6.01	251	
	Badarpur TPS (NTPC) (3*95+2*210)	705	168	167	3.64	151	
	Thermal (Total)	2917	601	608	14.29	595	
	Wind Power	0	0	0	0.00	0	
	Biomass	16	0	0	0.00	0	
	Solar	2	0	0	0.00	0	
	Renewable(Total)	18	0	0	0.00	0	
Total Delhi	2935	601	608	14.29	595		
HP	Baspa HPS (IPP) (3*100)	300	0	0	1.25	52	
	Malana HPS (IPP) (2*43)	86	11	0	0.60	25	
	Other Hydro (>25MW)	372	220	129	3.98	166	
	Wind Power	0	0	0	0.00	0	
	Biomass	0	0	0	0.00	0	
	Solar	0	0	0	0.00	0	
	Small Hydro (< 25 MW)	486	270	213	5.53	230	
	Renewable(Total)	486	270	213	5.53	230	
	Total HP	1244	501	343	11.36	473	
J & K	Baglihar HPS (IPP) (3*150+3*150)	900	451	447	10.74	447	
	Other Hydro/IPP(including 98 MW Small Hydro)	308	136	120	2.86	119	
	Gas/Diesel/Others	190	0	0	0.00	0	
	Wind Power	0	0	0	0.00	0	
	Biomass	0	0	0	0.00	0	
	Solar	0	0	0	0.00	0	
	Small Hydro (< 25 MW)Included in Other Hydro Above	98	0	0	0.00	0	
	Renewable(Total)	98	0	0	0.00	0	
Total J & K	1398	587	567	14	567		
Total State Control Area Generation	50738	15529	17080	368.12	15338		
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		7819	7057	149.14	6214		
Total Regional Availability(Gross)	76635	41191	35255	797.65	33235		
IV. Total Hydro Generation:							
Regional Entities Hydro	12234	9183	3065	108.69	4529		
State Control Area Hydro	7163	2361	1968	42.50	2023		
Total Regional Hydro	19397	11544	5033	151.19	6552		
V. Total Renewable Generation:							
Regional Entities Renewable	30	0	0	0.14	6		
State Control Area Renewable	7356	427	343	10.53	439		

Total Regional Renewable	7386	427	343	10.67	445
--------------------------	------	-----	-----	-------	-----

VI(A). Inter Regional Exchange [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(20:00 Hrs) MW	Off Peak(03:00 Hrs) MW	Maximum Interchange (MW)		Energy (MU)		Net Energy MU
			Import	Export	Import	Export	
Vindhychal(HVDC B/B)	-250	-500	0	500	0.00	8.76	-8.76
765 KV Gwalior-Agra (D/C)	2365	2174	2365	0	42.68	0.00	42.68
400 KV Zerda-Kankroli	-23	-43	0	251	0.00	2.15	-2.15
400 KV Zerda-Bhinmal	-51	-36	81	187	0.00	0.56	-0.56
220 KV Auraiya-Malanpur	-43	-11	0	66	0.00	0.82	-0.82
220 KV Badod-Kota/Morak	41	10	61	33	0.38	0.00	0.38
Mundra-Mohindergarh(HVDC Bipole)	2000	1499	2005	0	37.23	0.00	37.23
400 KV RAPPC-Sujalpur	340	250	398	0	6.46	0.00	6.46
400 KV Vindhychal-Rihand	0	0	0	0	0.00	0.00	0.00
765 kv Phagi-Gwalior (D/C)	1213	1169	1635	0	28.07	0.00	28.07
+/- 800 kv HVDC Champa-Kurushetra	1500	1500	1500	0	24.38	0	24.38
Sub Total WR	7092	6012			139.21	12.29	126.92
400 kv Sasaram - Varanasi	171	160	183	0	3.80	0.00	3.80
400 kv Sasaram - Allahabad	-31	-23	0	47	0.00	0.35	-0.35
400 KV MZP- GKP (D/C)	0	0	0	0	0.00	0.00	0.00
400 KV Patna-Balia(D/C) X 2	356	508	607	0	8.73	0.00	8.73
400 KV B'Sharif-Balia (D/C)	-81	-38	0	106	0.00	1.30	-1.30
765 KV Gaya-Balia	120	130	196	0	2.78	0.00	2.78
765 KV Gaya-Varanasi (D/C)	142	69	350	0	2.23	0.00	2.23
220 KV Pusauli-Sahupuri	227	211	227	0	4.16	0.00	4.16
132 KV K'nasa-Sahupuri	0	0	0	0	0.00	0.00	0.00
132 KV Son Ngr-Rihand	-36	-40	0	42	0.00	0.84	-0.84
132 KV Garhwa-Rihand	0	0	0	0	0.00	0.00	0.00
765 KV Sasaram - Fatehpur	-328	-265	0	328	0.00	4.85	-4.85
400 KV Barh -GKP (D/C)	0	0	0	0	0.00	0.00	0.00
400 kv B'Sharif - Varanasi (D/C)	-208	-160	0	242	0.00	3.90	-3.90
+/- 800 KV HVDC Alipurduar-Agra	0	0	0	0	0.00	0.00	0.00
Sub Total ER	332	552			21.70	11.23	10.48
+/- 800 KV HVDC BiswanathCharialli-Agra	395	493	494	0.00	11.74	0.00	11.74
Sub Total NER	395	493			11.74	0.00	11.74
Total IR Exch	7819	7057			172.66	23.52	149.14

VI(B). Inter Regional Schedule & Actual Exchanges [Import (+ve)/Export (-ve)] [Corridor wise]

ISGS/LT Schedule (MU)			Bilateral Schedule (MU)		Power Exchange Shdl (MU)		Wheeling (MU)	
ER	Bhutan	Total	Through ER	Through WR	Through ER	Through WR	Through ER	Through WR
37.53	0.75	38.28	-1.34	-1.51	-2.36	4.47	0.00	0.00

Total IR Schedule (MU)			Total IR Actual (MU)			Net IR UI (MU)		
Through ER	Through WR Incls Mndra	Total	Through ER(including NER)	Through WR	Total	Through ER (including NER)	Through WR	Total
34.58	142.23	176.81	22.22	126.92	149.14	-12.36	-15.31	-27.67

VI(C). Inter National Exchange with Nepal [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(20:00 Hrs) MW	Off Peak(03:00 Hrs) MW	Maximum Interchange (MW)		Energy (MU)		Net Energy MU
			Import	Export	Import	Export	
132 KV Tanakpur - Mahendarnagar	-12	-11	0	29	0	1	-0.67

VII. Frequency Profile <----- % of Time Frequency ----->

<49.2	<49.7	<49.8	<49.9	<50.0	49.9-50.05	50.05-50.10	50.10-50.20	>50.20	>50.50
0.00	0.00	0.05	12.74	60.11	74.98	10.34	2.03	0.00	0.00

<----- Frequency (Hz) ----->				Average Frequency	Frequency Variation	Std. Dev.	Frequency in 15 Min Block		Freq Dev Index (% of Time)
Maximum		Minimum					MAX	MIN	
Freq	Time	Freq	Time	Hz	Index		(Hz)	(Hz)	
50.17	17.33	49.70	14.12	49.88	0.049	0.066	50.18	49.83	25.02

VIII(A). Voltage profile 400 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)				Volta ge Deviat
		Voltage(KV)	Time	Voltage (KV)	Time	<380 kV	<390 kV	>420 kV	>430 kV	
Rihand	400	413	12:17	401	19:15	0.0	0.0	0.0	0.0	0.0
Gorakhpur	400	427	12:59	388	19:11	0.0	0.9	25.6	0.0	25.6
Bareilly(PG)400kV	400	428	13:00	388	19:15	0.0	0.4	17.0	0.0	17.0
Kanpur	400	422	12:59	390	19:12	0.0	0.0	1.7	0.0	1.7
Dadri	400	427	13:02	398	19:11	0.0	0.0	34.7	0.0	34.7
Ballabgarh	400	426	13:04	292	14:45	20.0	20.0	21.3	0.0	41.3
Bawana	400	428	13:04	394	19:15	0.0	0.0	36.3	0.0	36.3
Bassi	400	426	13:04	396	19:12	0.0	0.0	18.5	0.0	18.5
Hissar	400	425	13:01	394	19:12	0.0	0.0	5.0	0.0	5.0
Moga	400	424	13:01	398	19:13	0.0	0.0	10.1	0.0	10.1
Abdullapur	400	430	13:01	398	19:27	0.0	0.0	50.5	0.0	50.5
Nalagarh	400	432	03:49	403	19:17	0.0	0.0	44.6	3.0	44.6
Kishenpur	400	419	02:44	398	19:13	0.0	0.0	0.0	0.0	0.0
Wagoora	400	400	03:45	375	19:27	11.4	75.4	0.0	0.0	11.4
Amritsar	400	430	02:40	405	19:14	0.0	0.0	41.6	0.0	41.6
Kashipur	400	0	00:00	0	00:00	0.0	0.0	0.0	0.0	0.0
Hamirpur	400	424	12:59	410	17:12	0.0	0.0	62.4	0.0	62.4
Rishikesh	400	403	15:02	403	15:02	0.0	0.0	0.0	0.0	0.0

VIII(B). Voltage profile 765 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)				Volta ge Deviat
		Voltage(KV)	Time	Voltage (KV)	Time	<728 kV	<742 kV	>800 kV	>820 kV	
Fatehpur	765	780	06:01	728	19:13	31.6	35.9	0.0	0.0	31.6
Balia	765	797	13:00	736	19:12	0.0	1.1	0.0	0.0	0.0
Moga	765	807	13:02	753	19:15	0.0	0.0	3.0	0.0	3.0
Agra	765	796	13:02	739	19:15	0.0	0.2	0.0	0.0	0.0
Bhiwani	765	814	13:00	759	19:16	0.0	0.0	37.2	0.0	37.2
Unnao	765	784	06:00	727	18:54	0.2	5.2	0.0	0.0	0.2
Lucknow	765	807	12:59	738	19:16	0.0	0.9	9.9	0.0	9.9
Meerut	765	812	10:41	739	19:13	0.0	0.5	25.4	0.0	25.4
Jhatikara	765	815	13:03	754	19:13	0.0	0.0	26.9	0.0	26.9
Bareilly 765 kV	765	814	12:59	742	19:10	0.0	0.0	18.8	0.0	18.8
Anta	765	805	13:03	766	19:14	0.0	0.0	3.1	0.0	3.1
Phagi	765	0	00:00	0	00:00	100.0	100.0	0.0	0.0	100.0

Note : '0' in Max / Min Col -> Telemetry Outage

IX. Reservoir Parameters:

Name of Reservoir	Parameters		Present Parameters		Last Year		Last day	
	FRL (m)	MDDL (m)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (m ³ /s)	Usage (m ³ /s)
Bhakra	513.59	445.62	465.24	195.49	479.47	447.73	301.66	229.28

Pong	426.72	384.05	396.90	157.28	395.83	141.12	60.26	39.90
Tehri	829.79	740.04	758.95	112.67	749.30	44.52	56.90	167.00
Koteshwar	612.50	598.50	611.04	5.20	611.71	5.44	167.00	166.34
Chamera-I	760.00	748.75	752.03	0.00	0.00	0.00	216.63	356.49
Rihand	268.22	252.98	0.00	0.00	0.00	0.00	0.00	0.00
RPS	352.80	343.81	0.00	0.00	0.00	0.00	0.00	0.00
Jawahar Saagar	298.70	295.78	0.00	0.00	0.00	0.00	0.00	0.00
RSD	527.91	487.91	510.94	0.71	496.23	3.68	317.92	27.08

* NA: Not Available

X(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00 Hrs)			Peak Hours (20:00 Hrs)			Day Energy (MU)		
	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MU)	IEX / PXIL (MU)	Total (MU)
Punjab	-99	0	0	-99	0	0	-2.37	0.00	-2.37
Delhi	-259	-390	0	-295	28	0	-4.89	-2.16	-7.05
Haryana	33	215	0	33	230	0	-1.63	2.76	1.13
HP	81	-94	0	74	-767	0	1.91	-6.29	-4.38
J&K	-46	0	0	-46	-14	0	-1.10	1.10	0.00
CHD	0	0	0	0	0	0	0.00	0.38	0.38
Rajasthan	22	225	0	23	373	0	0.59	8.39	8.98
UP	30	-56	0	99	350	0	1.57	0.56	2.13
Uttarakhand	209	-41	0	119	46	0	4.93	1.09	6.02
Total	-28	-140	0	-92	247	0	-1.00	5.83	4.84

X(B). Short-Term Open Access Details:

State	Bilateral (MW)		IEX (MW)		PXIL (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Punjab	-99	-99	0	0	0	0
Delhi	-97	-443	172	-623	0	0
Haryana	33	-169	267	-499	0	0
HP	83	74	-92	-988	0	0
J&K	-46	-46	174	-115	0	0
CHD	0	0	64	-20	0	0
Rajasthan	31	17	432	-113	0	0
UP	99	10	806	-56	0	0
Uttarakhand	246	117	322	-181	0	0

XI. System Reliability Indices (Violation of TTC and ATC):

(i) %age of times N-1 Criteria was violated in the inter - regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(ii) %age of times ATC violated on the inter-regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(iii) %age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand - Dadri	0.00%
----------------	-------

XII. Zero Crossing Violations

State	No. of violations(Maximum 8 in a day)	Maximum number of continuous blocks without sign change
Punjab	3	19
Haryana	2	22
Rajasthan	0	12
Delhi	6	65
UP	4	40
Uttarakhand	6	75
HP	3	43
J & K	3	31
Chandigarh	1	13

XIII. System Constraints:

XIV. Grid Disturbance / Any Other Significant Event:

XV. Weather Conditions For 10.04.2017 :

XVI. Synchronisation of new generating units :

XVII. Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / substation :

XVIII. Tripping of lines in pooling stations :

XIX. Complete generation loss in a generating station :

Note: Data (regarding drawal, generation, shortage, inter-regional flows and reservoir levels) of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.