

पॉवर सिस्टम ऑपरेशन कापरिशन लिमिटेड
(पॉवरग्रिड की पूर्ण स्वामित्व प्राप्त सहायक कंपनी)
उत्तरी क्षेत्रीय भार प्रेषण केंद्र
CIN: U40105DL2009GOI188682
Power Supply Position in Northern Region for 11.05.2016
Date of Reporting : 12.05.2016



I. Regional Availability/Demand:

Evening Peak (20:00 Hrs) MW				Off Peak (03:00 Hrs) MW				Day Energy (Net MU)	
Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage
42849	548	43397	50.08	36718	338	37056	50.03	958.8	10.64

* Half hourly (two 15 minutes block-one block each before and after the designated time) average frequency

II. A. State's Load Details (At States periphery) in MUs:

State	State's Control Area Generation (Net MU)				Drawal Schedule (Net MU)	Actual Drawal (Net MU)	UI (Net MU)	Consumption (Net MU)	Shortages *
	Thermal	Hydro	Renewable/others \$	Total					
Punjab	49.43	9.68		59.11	74.53	74.06	-0.47	133.17	0.00
Haryana	24.65	0.60		25.25	98.14	96.43	-1.71	121.68	0.00
Rajasthan	122.49	0.00	16.08	138.57	60.38	62.29	1.91	200.86	0.00
Delhi	16.98			16.98	85.12	83.96	-1.17	100.94	0.14
UP	150.29	10.60		160.89	139.71	137.07	-2.65	297.96	0.00
Uttarakhand		15.87		15.87	22.36	19.55	-2.81	35.43	0.16
HP		15.66		15.66	6.16	6.78	0.62	22.44	0.01
J & K		19.89	0.00	19.89	18.57	21.43	2.87	41.33	10.33
Chandigarh				0.00	5.48	5.04	0.27	5.04	0.00
Total	363.85	72.31	16.08	452.24	510.46	506.60	-3.15	958.84	10.64

* Shortage furnished by the respective constituent \$ Others include UP Co-generation and JK Diesel

II. B. State's Demand Met in MWs:

State	Evening Peak (20:00 Hrs) MW				Off Peak (03:00 Hrs) MW				# Max(hourly) Demand Met of Day (MW)
	Demand Met	Shortage	UI	STOA/PX transaction	Demand Met	Shortage	UI	STOA/PX transaction	
Punjab	5802	0	41	-179	4221	0	-263	271	6599
Haryana	6488	0	-266	530	4542	0	-428	533	6807
Rajasthan	7980	0	-115	171	8083	0	319	-183	9299
Delhi	4325	0	-91	533	3907	20	-121	62	5044
UP	13149	0	-245	1126	12248	0	-717	2295	13938
Uttarakhand	1772	40	176	331	1539	0	35	267	1772
HP	1073	0	49	-1272	774	0	261	-1318	1157
J&K	2032	508	200	-545	1274	318	-212	-646	2087
Chandigarh	228	0	-23	0	130	0	-47	0	254
Total	42849	548	-274	696	36718	338	-1173	1281	45669

* STOA figures are at sellers boundary & PX figures are at regional boundary. # figures may not be at simultaneous hour.

III. Regional Entities :

Station/Constituent	Inst. Capacity (Effective) MW	Declared Capacity(MW)	Peak MW (Gross)	Off Peak MW	Energy (Net MU)	Average Sentout(MW)	Schedule Net MU	UI Net MU
A. NTPC								
Singrauli STPS (5*200+2*500)	2000	1397	1553	1109	33.37	1391	28.69	4.69
Rihand I STPS (2*500)	1000	776	856	602	15.80	658	15.42	0.37
Rihand II STPS (2*500)	1000	961	1039	697	18.76	782	19.07	-0.32
Rihand III STPS (2*500)	1000	962	1012	681	18.80	783	19.70	-0.89
Dadri I STPS (4*210)	840	805	439	425	9.60	400	9.73	-0.13
Dadri II STPS (2*490)	980	970	693	692	15.60	650	16.14	-0.54
Unchahar I TPS (2*210)	420	350	294	265	6.17	257	6.21	-0.04
Unchahar II TPS (2*210)	420	400	310	301	6.86	286	6.98	-0.12
Unchahar III TPS (1*210)	210	200	141	140	3.33	139	3.52	-0.19
ISTPP (Jhajjar) (3*500)	1500	1425	10025	926	21.71	905	21.92	-0.21
Dadri GPS (4*130,19+2*154.51)	830	692	346	392	7.86	328	8.26	-0.39
Anta GPS (3*88.71+1*153.2)	419	395	199	156	4.13	172	4.07	0.06
Auraya GPS (4*111.19+2*109.30)	663	620	149	110	3.48	145	3.20	0.28
Dadri Solar(5)	5	1	0	0	0.02	1	0.02	0.00
Unchahar Solar(10)	10	2	0	0	0.04	2	0.05	0.00
Singrauli Solar(15)	15	3	0	1	0.07	3	0.07	0.00
KHEPI(4*200)	800	872	867	604	16.09	670	16.00	0.09
Sub Total (A)	12112	10830	17922	7101	182	7570	179	3
B. NPC								
NAPS (2*220)	440	388	195	195	4.60	192	9.31	-4.71
RAPS- B (2*220)	440	367	412	421	8.97	374	6.50	2.47
RAPS- C (2*220)	440	415	438	445	9.45	394	9.96	-0.51
Sub Total (B)	1320	1170	1045	1061	23.01	959	25.77	-2.76
C. NHPC								
Chamera I HPS (3*180)	540	535	546	0	9.88	412	9.71	0.17
Chamera II HPS (3*100)	300	300	307	110	6.81	284	6.76	0.05
Chamera III HPS (3*77)	231	231	234	83	5.22	217	5.23	-0.01
Bairasul HPS(3*60)	180	179	185	58	3.19	133	3.07	0.13
Salal-HPS (6*115)	690	626	670	666	15.55	648	15.05	0.50
Tanakpur-HPS (3*31.4)	94	31	31	29	0.79	33	0.74	0.05
Uri-I HPS (4*120)	480	475	476	475	11.57	482	11.40	0.17
Uri-II HPS (4*60)	240	235	241	240	5.67	236	5.65	0.02
Dhauliganga-HPS (4*70)	280	280	149	8	2.83	118	2.54	0.29
Dulnasti-HPS (3*130)	390	387	406	403	9.52	397	9.29	0.23
Sewa-II HPS (3*40)	120	119	129	32	1.50	62	1.50	0.00
Parbati 3 (4*130)	520	260	265	132	2.29	95	2.23	0.06
Sub Total (C)	4065	3660	3639	2238	75	3117	73	2
D.SJVNL								
NJPC (6*250)	1500	1605	1620	1259	37.37	1557	37.22	0.15
Rampur HEP (6*68.67)	412	393	447	375	9.45	394	9.33	0.12
Sub Total (D)	1912	1998	2067	1634	46.82	1951	46.55	0.26
E. THDC								
Tehri HPS (4*250)	1000	256	258	0	3.50	146	3.50	0.00
Koteswar HPS (4*100)	400	56	101	0	1.36	57	1.34	0.02
Sub Total (E)	1400	312	359	0	4.86	202	4.84	0.02
F. BBMB								
Bhakra HPS (2*108+3*126+5*157)	1379	635	1160	372	15.42	643	15.25	0.17
Dehar HPS (6*165)	990	622	660	620	14.96	623	14.93	0.04
Pong HPS (6*66)	396	78	200	0	1.79	75	1.86	-0.07
Sub Total (F)	2765	1335	2020	992	32.18	1341	32.04	0.14
G. IPP(s)/JV(s)								
ALLAIN DUHANGAN HPS(IPP) (2*1000)	192	0	108	110	2.47	103	2.59	-0.12
KARCHAM WANGTOO HPS(IPP) (2*1000)	1000	0	1050	900	21.18	883	21.82	-0.64
Malana Stq-II HPS (2*50)	100	0	111	45	1.13	47	1.06	0.07
Shree Cement TPS (2*150)	300	0	144	146	3.48	145	3.66	-0.18
Budhil HPS(IPP) (2*35)	70	0	38	39	0.91	38	0.94	-0.04
Sub Total (G)	1662	0	1452	1239	29.17	1215	30.07	-0.90
H. Total Regional Entities (A-G)	25237	19305	28504	14265	392.53	16355	391.45	1.08

I. State Entities	Station	Effective Installed Capacity (MW)	Peak MW	Off Peak MW	Energy(MU)	Average(Sent out MW)	
Punjab	Guru Gobind Singh TPS (Ropar) (6*210)	1260	350	540	9.15	381	
	Guru Nanak Dev TPS(Bhatinda) (2*110+2*120)	460	100	100	2.28	95	
	Guru Hargobind Singh TPS(L.mbt) (2*210+2*250)	920	539	546	13.28	553	
	Goindwal(GVK) (2*270)	540	0	0	-0.04	-2	
	Rajpura (2*700)	1400	810	330	15.26	636	
	Talwandi Saboo (3*660)	1980	450	308	9.51	386	
	Thermal (Total)	6560	2249	1824	49.43	2060	
	Total Hydro	1000	420	367	9.68	403	
	Total Punjab	7560	2669	2191	59.11	2463	
	Haryana	Panipat TPS (4*110+2*210+2*250)	1367	0	400	2.49	104
DCRTPP (Yamuna nagar) (2*300)		600	0	232	1.02	43	
Faridabad GPS (NTPC)(2*137.75+1*156)		432	185	166	3.93	164	
RGTPP (kheadar) (IPP) (2*600)		1200	548	743	11.28	470	
Magnum Diesel (IPP)		25	0	0	0.00	0	
Jhajjar(CLP) (2*660)		1320	559	0	5.93	247	
Thermal (Total)		4944	1292	1541	24.65	1027	
Total Hydro		62	26	25	0.60	25	
Total Haryana		5006	1318	1566	25.25	1052	
Rajasthan		kota TPS (2*110+2*195+3*210)	1240	774	771	18.39	766
	suratgarh TPS (6*250)	1500	587	577	14.17	590	
	Chabra TPS (4*250)	1000	800	752	19.56	815	
	Dholpur GPS (3*110)	330	98	98	2.54	106	
	Rangarh GPS(1*37.5 + 1*35.5 +2*37.5 +1*110 +1*50)	271	136	149	3.39	141	
	RAPS A (NPC) (1*100+1*200)	300	0	0	0.00	0	
	Barsingar (NLC) (2*125)	250	80	82	1.84	77	
	Giral LTPS (2*125)	250	0	0	0.00	0	
	Rajwst LTPS (IPP) (8*135)	1080	403	391	14.12	588	
	VS LIGNITE LTPS (IPP) (1*135)	135	0	0	0.00	0	
	Kalsindh Thermal(2*600)	1200	820	812	21.97	916	
	Kawal(Adani) (2*660)	1320	861	1125	26.51	1104	
	Thermal (Total)	8876	4559	4757	122	5104	
	Total Hydro	550	0	0	0.00	0	
	Wind power	3214	719	901	12.42	518	
	Biomass	99	22	22	0.54	22	
	Solar	730	1	0	3.12	130	
	Renewable/Others (Total)	4043	742	923	16.08	670	
	Total Rajasthan	13469	5301	5680	138.57	5774	
	UP	Anpara TPS (3*210+2*500)	1630	1406	1409	31.20	1300
Obra TPS (2*50+2*94+5*200)		1194	469	608	13.50	563	
Paricha TPS (2*110+2*220+2*250)		1160	885	681	22.00	917	
Panki TPS (2*105)		210	63	131	2.60	108	
Harduaganj TPS (1*60+1*105+2*250)		665	518	403	10.50	438	
Tanda TPS (NTPC) (4*110)		440	380	300	7.39	308	
Roza TPS (IPP) (4*300)		1200	738	725	18.90	788	
Anpara-C (IPP) (2*600)		1200	1076	854	21.10	879	
Bajaj Energy Pvt.Ltd(IPP) TPS (10*45)		450	283	283	6.50	271	
Anpara-D(2*500)		1000	0	0	0.00	0	
Lalitpur TPS(3*660)		1980	0	350	5.60	233	
Bara(2*660)		1320	357	356	8.60	358	
Thermal (Total)		12449	6175	6100	148	6162	
Vishnuparyag HPS (IPP)(4*110)		440	375	291	7.20	300	
Alakanada(4*82.5)		330	183	83	2.50	104	
Other Hydro		527	42	40	0.90	38	
Cogeneration		981	100	100	2.40	100	
Total UP		14727	6875	6614	161	6704	
Uttarakhand		Total Hydro	1398	524	704	15.87	661
		Total Uttarakhand	1398	524	704	15.87	661
Delhi	Rajghat TPS (2*67.5)	135	0	0	0.00	0	
	Delhi Gas Turbine (6x30 + 3x34)	282	72	74	1.83	76	
	Pragati Gas Turbine (2x104+ 1x122)	330	262	151	4.59	191	
	Rithala GPS (3*36)	95	0	0	0.00	0	
	Bawana GPS (4*216+2*253)	1370	253	252	6.07	253	
	Badarpur TPS (NTPC) (3*95+2*210)	705	161	311	4.50	187	
	Thermal (Total)	2917	748	787	16.98	708	
	Total Delhi	2917	748	787	16.98	708	
HP	Baspa HPS (IPP) (3*100)	300	338	338	6.40	267	
	Malana HPS (IPP) (2*43)	86	60	63	1.02	42	
	Other Hydro	878	359	353	8.24	343	
	Total HP	1264	757	754	15.66	652	
J & K	Baglihar HPS (IPP) (3*150+2*150)	750	735	735	17.64	735	
	Other Hydro/IPP	560	118	82	2.25	94	
	Gas/Diesel/Others	190	0	0	0.00	0	
	Total J & K	1500	853	817	19.89	829	
Total State Control Area Generation		47841	19045	19113	452.24	18843	
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]			6872	4265	130.02	5418	
Total Regional Availability(Gross)		73078	54422	37642	974.80	40616	

IV. Total Hydro Generation:

Regional Entities Hydro	12234	10222	6522	199.54	8314
State Control Area Hydro	6881	3180	3081	72	3013
Total Regional Hydro	19115	13402	9603	271.84	11327

(VA). Inter Regional Exchange [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(20:00 Hrs)		Off Peak(03:00 Hrs)		Maximum Interchange (MW)		Energy (MU)		Net Energy MU
	MW	MW	MW	MW	Import	Export	Import	Export	
Vindhyachal(HVDC B/B)	0	-250	250	250	0.16	2.76		-2.61	
765 KV Gwalior-Agra (D/C)	2499	1555	3392	0	56.10	0.00		56.10	
400 KV Zerda-Kankroli	-115	-342	0	342	0.00	5.11		-5.11	
400 KV Zerda-Bhinmal	-67	-258	0	269	0.00	3.19		-3.19	
220 KV Auraiya-Malanpur	-45	-78	0	92	0.00	0.66		-0.66	
220 KV Badod-Kota/Morak	-26	-73	38	83	0.77	0.00		0.77	
Mundra-Mohindergarh(HVDC Bipole)	2498	1998	2506	0	50.17	0.00		50.17	
400 KV Vindhyachal - Rihand	0	0	0	0	0.00	0.00		0.00	
765 kV Phagi-Gwalior (D/C)	618	-41	836	193	4.86	0.00		4.86	
Sub Total WR	5362	2511			112.06	11.72		100.34	

Pusaui Bypass/HVDC	0	400	400	0	3.52	0.00	3.52
400 KV MZP- GKP (D/C)	-7	192	192	78	1.51	0.00	1.51
400 KV Patna-Balia(D/C) X 2	417	238	458	0	7.10	0.00	7.10
400 KV B'Sharif-Balia (D/C)	4	59	185	0	1.49	0.00	1.49
765 KV Gaya-Balia	178	170	350	0	2.63	0.00	2.63
765 KV Gaya-Varanasi (D/C)	43	115	24	115	0.00	1.40	-1.40
220 KV Pusaui-Sahupuri	177	195	195	0	4.23	0.00	4.23
132 KV K'nasa-Sahupuri	0	0	0	0	0.00	0.00	0.00
132 KV Son Ngr-Rihand	-26	-30	0	-30	0.00	0.57	-0.57
132 KV Garhwa-Rihand	0	0	0	0	0.00	0.00	0.00
765 KV Sasaram - Fatehpur	-142	-266	0	285	0.00	4.35	-4.35
400 KV Barh -GKP (D/C)	502	316	502	0	8.03	0.00	8.03
400 kvB'Sharif - Varanasi (D/C)	-122	-121	0	227	0.00	3.41	-3.41
Sub Total ER	1024	1268			28.51	9.72	18.79
+/- 800 KV BiswanathCharialli-Agra	486	486	487	0	10.90	0.00	10.90
Sub Total NER	486	486			10.90	0.00	10.90
Total IR Exch	6872	4265			151.47	21.44	130.02

V(B). Inter Regional Schedule & Actual Exchanges [Import (+ve)/Export (-ve)] [Corridor wise]

ISGS/LT Schedule (MU)			Bilateral Schedule (MU)		Power Exchange Shdl (MU)		Wheeling (MU)	
ER	Bhutan	Total	Through ER	Through WR	Through ER	Through WR	Through ER	Through WR
30.19	0.71	30.90	2.41	7.04	-0.56	-0.55	0.00	0.00

Total IR Schedule (MU)			Total IR Actual (MU)			Net IR UI (MU)		
Through ER	Through WR Inclds Mndra	Total	Through ER (including NER)	Through WR	Total	Through ER (including NER)	Through WR	Total
32.75	108.18	140.93	29.69	100.34	130.02	-3.07	-7.84	-10.91

V(C). Inter National Exchange with Nepal [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(20:00 Hrs)	Off Peak(03:00 Hrs)	Maximum Interchange (MW)		Energy (MU)		Net Energy MU
	MW	MW	Import	Export	Import	Export	
132 KV Tanakpur - Mahendarnagar	-30	-28	0	31	0	1	-0.69

VI. Frequency Profile <----- % of Time Frequency ----->

<49.2	<49.7	<49.8	<49.9	<50.0	49.9-50.05	50.05-50.10	50.10-50.20	>50.20	>50.50
0.00	0.00	0.16	5.10	42.29	67.09	22.14	6.10	0.05	0.00

Frequency (Hz) <----->				Average Frequency	Frequency Variation	Std. Dev.	Frequency in 15 Min Block		Freq Dev Index (% of Time)
Maximum		Minimum					MAX	MIN	
Freq	Time	Freq	Time	Hz	Index	(Hz)	(Hz)		
50.21	17.02	49.74	19.40	50.01	0.042	0.064	50.22	49.96	32.91

VII. Voltage profile 400 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)				Voltage Deviation Index (% of)
		Voltage(KV)	Time	Voltage (KV)	Time	<380 kV	<390 kV	>420 kV	>430 kV	
Rihand	400	414	6:38	402	22:35	0.0	0.0	0.0	0.0	0.0
Gorakhpur	400	426	7:34	394	22:33	0.0	0.0	10.8	0.0	10.8
Bareilly(PG)400kV	400	0	0:00	0	0:00	0.0	0.0	0.0	0.0	0.0
Kanpur	400	422	7:01	395	22:33	0.0	0.0	2.0	0.0	2.0
Dadri	400	426	4:03	398	22:34	0.7	0.7	20.3	0.0	21.0
Ballabgarh	400	430	4:00	399	22:35	0.0	0.0	29.3	0.0	29.3
Bawana	400	426	4:03	398	22:35	0.0	0.0	21.6	0.0	21.6
Bassi	400	423	4:00	390	23:03	0.0	0.0	3.2	0.0	3.2
Hissar	400	422	4:00	393	22:37	0.0	0.0	1.5	0.0	1.5
Moga	400	421	4:03	396	22:35	0.0	0.0	0.3	0.0	0.3
Abdullapur	400	426	4:02	399	19:40	0.0	0.0	20.4	0.0	20.4
Nalagarh	400	429	4:04	403	14:51	0.0	0.0	24.1	0.0	24.1
Kishenpur	400	416	3:10	396	15:28	0.0	0.0	0.0	0.0	0.0
Wagoora	400	409	3:10	382	20:05	0.0	18.7	0.0	0.0	0.0
Amritsar	400	430	3:16	165	8:48	0.0	0.0	20.4	0.0	20.5
Kashipur	400	422	4:03	407	19:40	0.0	0.0	15.1	0.0	15.1
Hamirpur	400	424	4:47	397	15:46	0.0	0.0	6.8	0.0	6.8
Rishikesh	400	419	5:01	377	22:09	1.1	36.4	0.0	0.0	1.1

VIII. Voltage profile 765 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)				Voltage Deviation Index (% of)
		Voltage(KV)	Time	Voltage (KV)	Time	<728 kV	<742 kV	>800 kV	>820 kV	
Fatehpur	765	789	7:02	730	22:34	0.0	15.7	0.0	0.0	0.0
Balia	765	797	7:02	730	22:34	0.0	17.9	0.0	0.0	0.0
Moga	765	807	4:03	756	22:36	0.0	0.0	6.5	0.0	6.5
Agra	765	794	3:09	740	22:36	0.0	0.5	0.0	0.0	0.0
Bhiwani	765	792	2:37	765	0:00	0.0	0.0	0.0	0.0	0.0
Unnao	765	779	3:15	723	22:35	1.1	32.0	0.0	0.0	1.1
Lucknow	765	800	7:02	739	22:35	0.0	0.4	0.0	0.0	0.0
Meerut	765	814	4:03	755	22:36	0.0	0.0	12.3	0.0	12.3
Jhatikara	765	804	4:02	749	22:35	0.0	0.0	10.1	0.0	10.1
Bareilly 765 kV	765	797	7:01	740	22:35	0.0	0.3	0.0	0.0	0.0
Anta	765	780	18:02	756	11:40	0.0	0.0	0.0	0.0	0.0
Phagi	765	784	3:10	742	22:37	0.0	0.0	0.0	0.0	0.0

Note : '0' in Max / Min Col -> Telemetry Outage

IX. Reservoir Parameters:

Name of Reservoir	Parameters		Present Parameters		Last Year		Last day	
	FRL (m)	MDDL (m)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (m ³ /s)	Usage (m ³ /s)
Bhakra	513.59	445.62	475.03	350.94	485.78	610.73	824.44	556.28
Pong	426.72	384.05	392.97	93.10	405.32	352.07	96.99	148.66
Tehri	829.79	740.04	741.45	4.65	757.70	105.63	139.02	136.00
Koteshwar	612.50	598.50	606.89	3.13	610.15	4.95	136.00	89.82
Chamera-I	760.00	748.75	754.07	0.00	0.00	0.00	308.48	272.42
Rihand	268.22	252.98	0.00	0.00	0.00	0.00	0.00	0.00
RPS	352.80	343.81	0.00	0.00	0.00	0.00	0.00	0.00
Jawahar Sagar	298.70	295.78	0.00	0.00	0.00	0.00	0.00	0.00
RSD	527.91	487.91	500.93	3.07	523.40	7.18	187.85	133.41

* NA: Not Available

X(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00 Hrs)			Peak Hours (20:00 Hrs)			Day Energy (MU)		
	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MU)	IEX / PXIL (MU)	Total (MU)
Punjab	-28	299	0	-433	254	0	-2.30	7.12	4.83
Delhi	402	-340	0	451	82	0	10.98	-1.72	9.26
Haryana	195	339	0	211	319	0	5.88	6.88	12.76
HP	-484	-834	0	-229	-1043	0	-8.15	-19.49	-27.64
J&K	-581	-65	0	-530	-14	0	-13.60	-1.64	-15.23
CHD	0	0	0	0	0	0	0.35	0.12	0.47
Rajasthan	-510	327	0	-394	566	0	-10.22	12.23	2.01
UP	1613	682	0	1126	0	0	30.83	3.46	34.29
Uttarakhand	33	234	0	106	225	0	1.21	6.18	7.39
Total	640	641	0	308	388	0	14.99	13.14	28.13

X(B). Short-Term Open Access Details:

State	Bilateral (MW)		IEX (MW)		PXIL (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Punjab	-28	-433	318	232	0	0
Delhi	550	402	258	-513	0	0
Haryana	358	190	384	81	0	0
HP	-229	-638	-313	-1155	0	0
J&K	-480	-626	-14	-166	0	0
CHD	44	0	25	0	0	0
Rajasthan	-382	-510	568	158	0	0
UP	1622	1094	682	0	0	0
Uttarakhand	106	33	358	87	0	0

XI. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter - regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(ii)%age of times ATC violated on the inter-regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand - Dadri	0.00%
----------------	-------

XII. System Constraints:

XIII. Grid Disturbance / Any Other Significant Event:

XIV. Weather Conditions For 11.05.2016 :
Normal

XV. Synchronisation of new generating units :

XVI. Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / substation :
1. 765/400kV 1500MVA ICT-2 at Varanasi first time charged on no-load at 1742Hrs of 11.05.16

0.00

0.00

0.00

XVII. Tripping of lines in pooling stations :

XVIII. Complete generation loss in a generating station :

Note: Data (regarding drawal, generation, shortage, inter-regional flows and reservoir levels) of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.