

पॉवर सिस्टम ऑपरेशन कार्पोरेशन लिमिटेड

(पावरसिड की पूर्ण स्वामित्व प्राप्त सहायक कंपनी)



उत्तरी क्षेत्रीय भार प्रेषण केंद्र

CIN: U40105DL2009GOI188682

Power Supply Position in Northern Region for 13.01.2015
Date of Reporting : 14.01.2015

I. Regional Availability/Demand:

Demand Met	Evening Peak (19:00 Hrs) MW			Off Peak (03:00 Hrs) MW			Day Energy (Net MU)		
	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage
39716	2314	42030	50.08	30329	577	30905	50.17	834.4	48.10

* Half hourly (two 15 minutes block—one block each before and after the designated time) average frequency

II. A. State's Load Details (At States periphery) in MUs:

State	State's Control Area Generation (Net MU)				Drawal Schedule (Net MU)	Actual Drawal (Net MU)	UI (Net MU)	Consumption (Net MU)	Shortages* (MU)
	Thermal	Hydro	Renewable/others \$	Total					
Punjab	42.51	5.92		48.43	41.65	42.17	0.51	90.60	0.00
Haryana	71.29	0.42		71.70	47.17	45.88	-1.29	117.58	0.00
Rajasthan	120.24	5.05	7.99	133.27	71.91	77.31	5.41	210.59	0.00
Delhi	20.80			20.80	49.85	49.97	0.13	70.77	0.03
UP	148.00	5.00		153.00	80.45	81.82	1.37	234.82	40.15
Uttarakhand		10.38		10.38	25.29	26.02	0.73	36.39	0.46
HP		4.40		4.40	20.05	20.38	0.34	24.78	0.00
J & K		4.40	0.00	4.40	36.87	40.33	3.46	44.73	7.46
Chandigarh				0.00	3.92	4.13	0.27	4.13	0.00
Total	402.83	35.56	7.99	446.38	377.15	388.01	10.92	834.38	48.10

* Shortage furnished by the respective constituent. \$ Others include UP Co-generation and JK Diesel

II. B. State's Demand Met in MWs:

State	Evening Peak (19:00 Hrs) MW				Off Peak (03:00 Hrs) MW				# Max(hourly) Demand Met of Day (MW)
	Demand Met	Shortage	UI	STOA/PX transaction	Demand Met	Shortage	UI	STOA/PX transaction	
Punjab	4398	0	-125	-274	3123	0	170	-301	4844
Haryana	6382	0	-98	-858	3498	0	-62	-804	6382
Rajasthan	9405	0	338	734	8178	0	100	1109	9779
Delhi	3483	0	-109	-49	1711	2	-59	-978	4020
UP	10811	1890	93	89	9976	270	300	73	10811
Uttarakhand	1845	75	28	709	1263	0	109	390	1878
HP	1211	0	-21	368	750	0	4	421	1312
J&K	1976	349	62	658	1726	305	129	677	2192
Chandigarh	205	0	-11	19	103	0	15	-31	246
Total	39716	2314	158	1397	30329	577	707	557	39716

* STOA figures are at sellers boundary & PX figures are at regional boundary. # figures may not be at simultaneous hour.

Diversity is 1.04

III. Regional Entities :

Station/ Constituent	Inst. Capacity (Effective) MW	Declared Capacity(MW)	Peak MW (Gross)	Off Peak MW (Gross)	Energy (Net MU)	Average Sentout(MW)	Schedule Net MU	UI Net MU
A. NTPC								
Singrauli STPS (5*200+2*500)	2000	1450	1569	1455	37.20	1550	34.37	2.83
Rihand I STPS (2*500)	1000	886	454	883	15.90	662	20.97	-5.07
Rihand II STPS (2*500)	1000	900	970	793	22.04	918	21.03	1.01
Rihand III STPS (2*500)	1000	969	1002	746	22.46	936	22.61	-0.15
Dadri I STPS (4*210)	840	812	599	404	15.76	657	14.93	0.83
Dadri II STPS (2*490)	980	980	931	661	20.30	846	19.81	0.49
Unchahar I TPS (2*210)	420	405	413	325	9.31	388	9.25	0.06
Unchahar II TPS (2*210)	420	405	417	300	9.03	376	8.94	0.09
Unchahar III TPS (1*220)	210	202	206	140	4.47	186	4.45	0.02
ISTPP (Jhajjar) (3*500)	1500	1500	1210	881	21.04	877	24.10	-3.06
Dadri GPS (4*130.19+2*154.51)	830	848	411	408	9.17	382	8.43	0.75
Anta GPS (3*88.71+1*153.2)	419	427	259	198	6.07	253	5.90	0.18
Auraiva GPS (4*111.19+2*109.30)	663	679	170	177	4.11	171	3.86	0.25
Dadri Solar	5	1	0	0	0.02	1	0.02	-0.01
Unchahar Solar	10	3	0	0	0.00	0	0.07	-0.07
Singrauli Solar	15	0	0	0	0.00	0	0	0.00
Sub Total (A)	11312	10466	8611	7371	197	8203	199	-2
B. NPC								
NAPS (2*220)	440	373	413	421	9.10	379	8.95	0.15
RAPS- B (2*220)	440	392	434	436	9.43	393	9.41	0.03
RAPS- C (2*220)	440	220	236	236	5.03	210	5.28	-0.25
Sub Total (B)	1320	985	1083	1093	23.57	982	23.64	-0.08
C. NHPC								
Chamera I HPS (3*180)	540	534	546	0	1.69	70	1.96	-0.27
Chamera II HPS (3*100)	300	300	304	0	1.10	46	1.10	0.00
Chamera III HPS (3*77)	231	154	157	0	0.59	25	0.55	0.04
Bairasuli HPS(3*60)	180	179	124	0	0.41	17	0.36	0.05
Salal-HPS (6*115)	690	88	220	64	2.22	93	2.12	0.11
Tanakpur-HPS (3*40)	94	29	31	33	0.74	31	0.70	0.04
Uri-I HPS (4*120)	480	93	210	20	2.53	105	2.23	0.29
Uri-II HPS (4*60)	240	0	0	0	0.00	0	0.00	0.00
Dhauliganga-HPS (4*70)	280	139	139	0	0.97	41	0.93	0.04
Dulhasti-HPS (3*130)	390	258	269	0	2.80	117	2.70	0.10
Sewa-II HPS (3*40)	120	119	81	0	0.25	10	0.36	-0.11
Parbati 3 (4*130)	520	0	0	0	0.00	0	0.00	0.00
Sub Total (C)	4065	1893	2081	117	13	554	13	0
D. SJVNL								
NJPC (6*250)	1500	1350	1340	0	5.93	247	5.80	0.13
Rampur HEP (4*68.67)	275	346	296	0	1.48	62	1.51	-0.03
Sub Total (D)	1775	1696	1636	0	7.40	308	7.31	0.09
E. THDC								
Tehri HPS (4*250)	1000	1004	1000	0	9.17	382	8.50	0.67
Koteshwar HPS (4*100)	400	125	294	90	3.25	136	3.00	0.25
Sub Total (E)	1400	1129	1294	90	12.43	518	11.50	0.93
F. BBMB								
Bhakra HPS (3*108+2*126+6*157)	1514	554	1092	338	12.12	505	13.30	-1.18
Dehar HPS (6*165)	990	119	330	0	3.32	138	2.87	0.46
Pong HPS (6*66)	396	170	252	0	3.12	130	4.09	-0.97
Sub Total (F)	2900	844	1674	338	18.56	773	20.25	-1.69
G. IPP(s)/JV(s)								
ALLAIN DUHANGAN HPS(IPP) (2*96)	192	0	21	0	0.34	14	0.43	-0.09
KARCHAM WANGTOO HPS(IPP) (4*250)	1000	0	560	0	3.25	135	3.21	0.04
Malana Stg-II HPS (2*50)	100	0	0	0	0.00	0	0.00	0.00
Shree Cement TPS (2*150)	300	0	278	152	5.66	236	4.77	0.89
Budhil HPS(IPP)	70	0	0	0	0.00	0	0.00	0.00
Sub Total (G)	1662	0	859	152	9.24	385	8.40	0.84
H. Total Regional Entities (A-G)	24434	17013	17237	9161	281.37	11724	282.84	-1.47

I. State Entities	Station	Effective Installed Capacity (MW)	Peak MW	Off Peak MW	Energy(MU)	Average(Sent out MW)
Punjab	Guru Gobind Singh TPS (Ropar) (6*210)	1260	500	500	12.16	507
	Guru Nanak Dev TPS(Bhatinda) (4*110)	440	110	80	2.21	92
	Guru Hargobind Singh TPS(L.mbt) (2*210+2*250)	920	460	362	9.36	390
	Goindwal(GVK)		0	0	0.00	0
	Rajpura (2*700)	1400	490	353	10.49	437
	Talwandi Saboo (1*660)	660	347	348	8.30	346
	Thermal (Total)	4680	1907	1643	42.51	1771
	Total Hydro	1148	365	59	5.92	247
Total Punjab	5828	2272	1702	48.43	2018	
Haryana	Panipat TPS (4*110+2*210+2*250)	1367	667	607	15.05	627
	DCRTPP (Yamuna nagar) (2*300)	600	524	480	11.88	495
	Faridabad GPS (NTPC)	432	420	298	9.24	385
	RGTPP (khedar) (IPP) (2*600)	1200	1162	752	22.22	926
	Magnum Diesel (IPP)	25	0	0	0.00	0
	Jhajjar(CLP) (2*660)	1320	625	378	12.90	537
	Thermal (Total)	4944	3398	2515	71.29	2970
	Total Hydro	62	11	13	0.42	17
	Total Haryana	5006	3409	2528	71.70	2988
	Rajasthan	kota TPS (2*110+2*195+3*210)	1240	1095	996	25.77
suratgarh TPS (6*250)		1500	1308	1135	29.80	1242
Chabra TPS (3*250)		750	664	582	15.06	627
Dholpur GPS (3*110)		330	114	113	2.79	116
Ramgarh GPS (1*3 + 1*35.5 +2*37.5 +1*110 +1*50)		271	126	161	3.46	144
RAPS A (NPC) (1*100+1*200)		300	0	0	0.00	0
Barsingsar (NLC) (2*125)		250	188	188	4.32	180
Giral LTPS (2*125)		250	0	0	0.00	0
Rajwest LTPS (IPP) (8*135)		1080	853	445	16.67	694
VS LIGNITE LTPS (IPP) (1*135)		135	0	0	0.00	0
Kalisindh Thermal(1*600)		600	0	0	0.00	0
Kawai(Adani) (2*660)		1320	1006	815	22.38	933
Thermal (Total)		8026	5354	4435	120	5010
Total Hydro		550	169	93	5.05	210
Wind power		2798	396	565	7.66	319
Biomass		99	9	9	0.22	9
Solar		730	1	0	0.10	4
Renewable/Others (Total)		3627	406	574	7.99	333
Total Rajasthan	12203	5929	5102	133.27	5553	
UP	Anpara TPS (3*210+2*500)	1630	1367	1382	32.40	1350
	Obra TPS (2*50+2*94+5*200)	1194	355	344	8.30	346
	Paricha TPS (2*110+2*220+2*250)	1140	776	704	17.50	729
	Panki TPS (2*105)	210	45	77	1.00	42
	Harduaganj TPS (1*60+1*105+2*250)	665	230	231	5.50	229
	Tanda TPS (NTPC) (4*110)	440	362	300	8.60	358
	Roza TPS (IPP) (4*300)	1200	914	774	21.90	913
	Anpara-C (IPP) (2*600)	1200	1076	1382	25.60	1067
	Bajaj Energy Pvt.Ltd(IPP) TPS (10*45)	450	401	280	8.00	333
	Thermal (Total)	8129	5526	5474	128.80	5367
	Vishnuparyag HPS (IPP)	400	73	74	1.70	71
	Other Hydro	527	140	52	3.30	138
	Cogeneration	981	800	800	19.20	800
	Total UP	10037	6539	6400	153.00	6304
	Uttarakhand	Total Hydro	1398	614	350	10.38
Total Uttarakhand		1398	614	350	10.38	432
Delhi	Raighat TPS (2*67.5)	135	42	40	0.96	40
	Delhi Gas Turbine (6x30 + 3x34)	282	162	161	3.85	161
	Pragati Gas Turbine (2x104+ 1x122)	330	0	0	0.00	0
	Rithala GPS (3*36)	95	0	0	0.00	0
	Bawana GPS (6*250)	1370	313	290	7.39	308
	Badarpur TPS (NTPC) (3*95+2*210)	705	394	334	8.60	358
	Thermal (Total)	2917	911	825	20.80	867
Total Delhi	2917	911	825	20.80	867	
HP	Baspa HPS (IPP) (2*150)	300	0	0	0.99	41
	Malana HPS (IPP) (2*43)	86	0	0	0.20	8
	Other Hydro	728	195	76	3.21	134
	Total HP	1114	195	76	4.40	183
J & K	Baglihar HPS (IPP) (3*150)	450	150	120	3.27	136
	Other Hydro/IPP	436	79	20	1.14	47
	Gas/Diesel/Others	209	0	0	0.00	0
	Total J & K	1094	229	140	4.40	183
Total State Control Area Generation		39597	20098	17123	446.38	18528
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]			4266	3601	116.00	4833
Total Regional Availability(Gross)		64032	41601	29885	843.74	35085

IV. Total Hydro Generation:

Regional Entities Hydro	11432	7265	546	55.27	2303
State Control Area Hydro	5684	1723	783	35.56	1411
Total Regional Hydro	17116	8988	1329	90.83	3714

V(A). Inter Regional Exchange [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(19:00 Hrs)	Off Peak(03:00 Hrs)	Maximum Interchange (MW)		Energy (MU)		Net Energy MU
	MW	MW	Import	Export	Import	Export	
Vindhychal B/B	50	-100	100	100	0.87	0.73	0.14
Gwalior-Agra (D/C)	870	1282	1883	0	33.55	0.00	33.55
Zerda-Kankroli	-128	-44	111	146	0.00	0.67	-0.67
Zerda-Bhinmal	-45	54	300	86	1.41	0.00	1.41
Malanpur-Auraiya	-75	-70	0	110	0.00	2.19	-2.19
Badod-Kota/Morak	-18	-13	53	75	0.00	0.71	-0.71
Mundra-Mohindergarh(HVDC)	2002	1501	2102	0	45.45	0.00	45.45
Vindhychal - Rihand	398	279	500	0	8.83	0.00	8.83
Sub Total WR	3054	2889			90.11	4.30	85.81
Pusauli Bypass	100	100	100	0	2.45	0.00	2.45
MZP- GKP (D/C)	23	-10	186	191	0.56	0.00	0.56
Patna-Balia(D/C)	715	538	802	0	16.61	0.00	16.61
B'Sharif-Balia (D/C)	-18	-124	112	156	0.00	1.32	-1.32
Pusauli-Balia	0	-37	40	69	0.00	0.20	-0.20
Gaya-Fatehpur (765 Kv)	262	164	517	0	7.43	0.00	7.43
Pusauli-Sahupuri	122	124	158	0	3.06	0.00	3.06
K'nasa-Sahupuri	0	0	0	0	0.00	0.00	0.00
Son Ngr-Rihand	-43	-25	0	43	0.00	0.81	-0.81
Garhwa-Rihand	0	0	0	0	0.00	0.00	0.00
Sasaram - Fatehpur(765 KV)	51	-18	303	42	2.39	0.00	2.39
Sub Total ER	1212	712			32.50	2.32	30.18
Total IR Exch	4266	3601			122.61	6.62	116.00

V(B). Inter Regional Schedule & Actual Exchanges [Import (+ve)/Export (-ve)] [Corridor wise]

ER	ISGS/LT Schedule (MU)		Bilateral Schedule (MU)		Power Exchange Shdl (MU)		Wheeling (MU)	
	Bhutan	Total	Through ER	Through WR	Through ER	Through WR	Through ER	Through WR
30.69	0.26	30.95	13.07	-5.50	6.25	14.19	1.46	-1.46

Total IR Schedule (MU)			Total IR Actual (MU)			Net IR UI (MU)		
Through ER	Through WR Inclds Mndra	Total	Through ER	Through WR	Total	Through ER	Through WR	Total
51.74	68.86	120.60	30.18	85.81	116.00	-21.55	16.95	-4.60

VI. Frequency Profile ←----- % of Time Frequency ----->

<49.2	<49.7	<49.8	<49.9	<50.0	49.9-50.05	50.05-50.10	50.10-50.20	>50.20	>50.50
0.00	0.12	2.09	16.73	50.83	57.01	14.14	8.28	3.87	NA

←----- Frequency (Hz) ----->				Average Frequency (Hz)	Frequency Variation Index	Std. Dev. (Hz)	Frequency in 15 Min Block	
Maximum		Minimum					MAX (Hz)	MIN (Hz)
Freq	Time	Freq	Time					
50.39	12:28:48	49.68	12:43:12	50.00	0.10	0.10	50.38	49.86

VII. Voltage profile 400 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)			
		Voltage(KV)	Time	Voltage (KV)	Time	<380 kV	<390 kV	>420 kV	>430 kV
Rihand	400	408	03:20	401	09:13	0.0	0.0	0.0	0.0
Gorakhpur	400	414	00:00	396	10:19	0.0	0.0	0.0	0.0
Bareilly	400	423	00:00	401	10:19	0.0	0.0	13.0	0.0
Kanpur	400	424	03:02	401	10:19	0.0	0.0	13.8	0.0
Dadri	400	423	03:00	400	10:37	0.0	0.0	13.4	0.0
Ballabgarh	400	430	03:02	404	10:19	0.0	0.0	24.5	0.0
Bawana	400	428	02:00	408	07:47	0.0	0.0	26.7	0.0
Bassi	400	429	05:03	400	07:47	0.0	0.0	32.2	0.0
Hissar	400	417	02:03	397	10:39	0.0	0.0	0.0	0.0
Moga	400	422	00:58	402	12:04	0.0	0.0	6.9	0.0
Abdullapur	400	426	00:57	396	07:19	0.0	0.0	21.4	0.0
Nalagarh	400	431	03:01	393	10:38	0.0	0.0	36.5	0.5
Kishenpur	400	414	23:02	389	12:14	0.0	1.1	0.0	0.0
Wagoora	400	390	23:05	361	18:40	74.7	99.9	0.0	0.0

VIII. Voltage profile 765 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)			
		Voltage(KV)	Time	Voltage (KV)	Time	<728 kV	<742 kV	>800 kV	>820 kV
Fatehpur	765	781	03:29	741	07:47	0.0	0.4	0.0	0.0
Balia	765	0	00:00	9999	00:00	0.0	0.0	0.0	0.0
Moga	765	0	00:00	9999	00:00	0.0	0.0	0.0	0.0
Agra	765	796	03:36	764	06:56	0.0	0.0	0.0	0.0
Bhiwani	765	802	02:03	765	07:47	0.0	0.0	6.9	0.0
Unnao	765	776	03:26	739	10:19	0.0	2.0	0.0	0.0

IX. Reservoir Parameters:

Name of Reservoir	Parameters		Present Parameters		Last Year		Last day	
	FRL (m)	MDDL (m)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (m³/s)	Usage (m³/s)
Bhakra	513.59	445.62	494.96	903.28	498.86	1053.16	136.94	356.03
Pong	426.72	384.05	403.43	304.55	410.12	504.32	69.94	222.68
Tehri	829.79	740.04	804.60	696.77	806.85	740.81	37.46	219.00
Koteshwar	612.50	598.50	608.92	4.44	610.11	4.69	219.00	216.00
Chamera-I	760.00	748.75	759.34	30.00	757.21	23.16	51.35	45.20
Rihand	268.22	252.98	850.50	263.50	854.30	326.40	0.00	0.00
RPS	352.80	343.81	0.00	0.00	0.00	0.00	0.00	0.00
Jawahar Sagar	298.70	295.78	0.00	0.00	0.00	0.00	0.00	0.00
RSD	527.91	487.91	504.00	2.33	510.20	2.77	43.18	89.86

* NA: Not Available

X(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00 Hrs)			Peak Hours (19:00 Hrs)			Day Energy (MU)		
	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MU)	IEX / PXIL (MU)	Total (MU)
Punjab	-308	7	0	-277	3	0	-6.18	0.26	-5.92
Delhi	-942	-5	-31	-539	495	-5	-11.74	5.75	-5.99
Haryana	-947	142	0	-944	85	0	-23.26	-0.22	-23.48
HP	483	-61	0	453	-86	0	12.28	-2.56	9.72
J&K	683	-5	0	485	173	0	13.18	3.00	16.18
CHD	-31	0	0	0	19	0	-0.25	0.75	0.50
Rajasthan	486	621	2	486	247	2	15.62	9.36	24.99
UP	73	0	0	89	0	0	-1.32	0.00	-1.32
Uttarakhand	290	99	0	290	398	20	6.97	7.76	14.73
Total	-213	798	-29	44	1336	17	5.31	24.11	29.41

X(B). Short-Term Open Access Details:

State	Bilateral (MW)		IEX (MW)		PXIL (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Punjab	-226	-308	194	0	0	0
Delhi	17	-942	675	-46	-5	-31
Haryana	-944	-994	143	-396	0	0
HP	555	429	10	-637	0	0
J&K	683	437	270	-5	0	0
CHD	0	-31	73	0	0	0
Rajasthan	841	486	999	-14	2	2
UP	126	-312	0	0	0	0
Uttarakhand	290	290	426	99	44	0

XI. System Constraints:**XII. Grid Disturbance / Any Other Significant Event:****XIII. Weather Conditions For 13.01.2015 :**

1.Rain in Jammu and Punjab.

XIV. Synchronisation of new generating units :

0.00

XV. Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :**XVI. Tripping of lines in pooling stations :****XVII. Complete generation loss in a generating station :**