

I. State Entities	Station	Effective Installed Capacity (MW)	Peak MW	Off Peak MW	Energy(MU)	Average(Sent out MW)	
Punjab	Guru Gobind Singh TPS (Ropar) (6*210)	1260	160	160	3.54	148	
	Guru Nanak Dev TPS(Bhatinda) (2*110+2*120)	460	0	0	-0.02	-1	
	Guru Hargobind Singh TPS(L.mbt) (2*210+2*250)	920	0	0	-0.14	-6	
	Goindwal(GVK) (2*270)	540	0	0	-0.03	-1	
	Rajpura (2*700)	1400	1320	820	28.70	1196	
	Talwandi Saboo (3*660)	1980	780	616	18.70	779	
	Thermal (Total)	6560	2260	1596	50.75	2115	
	Total Hydro	1000	468	465	11.25	469	
	Wind Power	0	0	0	0.00	0	
	Biomass	288	20	20	0.49	20	
	Solar	560	0	0	0.33	14	
	Renewable(Total)	848	20	20	0.82	34	
	Total Punjab	8408	2748	2081	62.82	2617	
	Haryana	Panipat TPS (2*210+2*250)	920	204	199	4.91	204
		DCRTPP (Yamuna nagar) (2*300)	600	553	470	11.76	490
Faridabad GPS (NTPC)(2*137.75+1*1156)		432	0	0	0.00	0	
RGTPP (khedar) (IPP) (2*600)		1200	1098	772	19.67	820	
Magnum Diesel (IPP)		25	0	0	0.00	0	
Jhajjar(CLP) (2*660)		1320	0	0	0.00	0	
Thermal (Total)		4497	1855	1441	36.34	1514	
Total Hydro		62	33	31	0.71	29	
Wind Power		0	0	0	0.00	0	
Biomass		40	0	0	0.00	0	
Solar		0	0	0	0.00	0	
Renewable(Total)		40	0	0	0.00	0	
Total Haryana		4599	1888	1472	37.04	1543	
Rajasthan	kota TPS (2*110+2*195+3*210)	1240	1083	1140	26.94	1123	
	suratgarh TPS (6*250)	1500	210	198	5.55	231	
	Chabra TPS (4*250)	1000	859	780	19.88	828	
	Dholpur GPS (3*110)	330	0	0	0.00	0	
	Ramgarh GPS(1*37.5 + 1*35.5 +2*37.5 +1*110 +1*50)	271	113	113	2.84	118	
	RAPS A (NPC) (1*100+1*200)	300	0	0	0.00	0	
	Barsingsar (NLC) (2*125)	250	226	227	5.31	221	
	Giral LTPS (2*125)	250	0	0	0.00	0	
	Rajwest LTPS (IPP) (8*135)	1080	815	816	19.28	803	
	VS LIGNITE LTPS (IPP) (1*135)	135	0	0	0.00	0	
	Kalisindh Thermal(2*600)	1200	559	549	12.76	532	
	Kawai(Adani) (2*660)	1320	866	1207	25.18	1049	
	Thermal (Total)	8876	4731	5030	117.75	4906	
	Total Hydro	550	72	73	2.00	83	
	Wind power	4017	100	99	3.51	146	
	Biomass	99	20	20	0.49	20	
	Solar	1295	6	0	0.33	14	
	Renewable/Others (Total)	5411	126	119	4.33	180	
Total Rajasthan	14837	4929	5222	124.07	5170		
UP	Anpara TPS (3*210+2*500)	1630	995	589	21.09	879	
	Obra TPS (2*50+2*94+5*200)	1194	288	126	4.76	198	
	Paricha TPS (2*110+2*220+2*250)	1160	658	908	17.31	721	
	Panki TPS (2*105)	210	135	153	3.33	139	
	Harduaganj TPS (1*60+1*105+2*250)	665	383	528	10.76	448	
	Tanda TPS (NTPC) (4*110)	440	355	376	8.71	363	
	Roza TPS (IPP) (4*300)	1200	914	959	20.77	865	
	Anpara-C (IPP) (2*600)	1200	1071	972	23.89	995	
	Bajaj Energy Pvt.Ltd(IPP) TPS (10*45)	450	224	404	6.76	282	
	Anpara-D(2*500)	1000	890	885	21.15	881	
	Lalitpur TPS(3*660)	1980	539	595	12.46	519	
	Bara(2*660)	1320	594	0	9.62	401	
	Thermal (Total)	12449	7046	6495	160.60	6692	
	Vishnuparyag HPS (IPP)(4*110)	440	216	221	6.76	282	
	Alaknada(4*82.5)	330	164	164	3.33	139	
	Other Hydro	527	304	242	5.82	242	
	Cogeneration	981	50	50	1.20	50	
	Wind Power	0	0	0	0.00	0	
	Biomass	26	0	0	0.00	0	
	Solar	102	0	0	0.00	0	
Renewable(Total)	128	0	0	0.00	0		
Total UP	14855	7780	7172	177.71	7405		
Uttarakhand	Other Hydro	1250	595	431	11.37	474	
	Total Gas	225	259	261	6.11	255	
	Wind Power	0	0	0	0.06	3	
	Biomass	127	0	0	0.00	0	
	Solar	20	0	0	0.00	0	
	Small Hydro (< 25 MW)	180	0	0	0.00	0	
	Renewable(Total)	327	0	0	0.06	3	
Total Uttarakhand	1802	854	692	17.53	731		
Delhi	Rajghat TPS (2*67.5)	135	0	0	-0.01	-1	
	Delhi Gas Turbine (6x30 + 3x34)	282	78	79	1.87	78	
	Pragati Gas Turbine (2x104+ 1x122)	330	152	150	3.69	154	
	Rithala GPS (3*36)	95	0	0	0.00	0	
	Bawana GPS (4*216+2*253)	1370	250	250	6.03	251	
	Badarpur TPS (NTPC) (3*95+2*210)	705	330	330	7.26	302	
	Thermal (Total)	2917	810	809	18.84	785	
	Wind Power	0	0	0	0.00	0	
	Biomass	16	0	0	0.00	0	
	Solar	2	0	0	0.00	0	
Renewable(Total)	18	0	0	0.00	0		
Total Delhi	2935	810	809	18.84	785		

HP	Baspa HPS (IPP) (3*100)	300	0	99	2.18	91
	Malana HPS (IPP) (2*43)	86	45	36	0.69	29
	Other Hydro	372	115	145	3.51	146
	Wind Power	0	0	0	0.00	0
	Biomass	0	0	0	0.00	0
	Solar	0	0	0	0.00	0
	Small Hydro (< 25 MW)	486	156	148	3.61	150
	Renewable(Total)	486	156	148	3.61	150
	Total HP	1244	316	428	9.99	416
	J & K	Baglihar HPS (IPP) (3*150+3*150)	900	295	295	7.07
Other Hydro/IPP(including 98 MW Small Hydro)		308	138	93	2.77	115
Gas/Diesel/Others		190	0	0	0.00	0
Wind Power		0	0	0	0.00	0
Biomass		0	0	0	0.00	0
Solar		0	0	0	0.00	0
Small Hydro (< 25 MW)Included in Other Hydro Above		98	0	0	0.00	0
Renewable(Total)		98	0	0	0.00	0
Total J & K		1398	433	388	10	410
Total State Control Area Generation		50078	19758	18264	457.85	19077
J. Net Inter Regional Exchange [Import (+ve)/Export (-ve)]		8767	7879	206.69	8612	
Total Regional Availability(Gross)	75315	45756	35641	928.99	38708	

IV. Total Hydro Generation:

Regional Entities Hydro	12234	9884	1871	96.57	4024
State Control Area Hydro	7163	2860	2704	61.06	2801
Total Regional Hydro	19397	12743	4575	157.63	6825

V. Total Renewable Generation:

Regional Entities Renewable	30	0	0	0.12	5
State Control Area Renewable	7356	303	287	8.81	367
Total Regional Renewable	7386	303	287	8.93	372

VI(A). Inter Regional Exchange [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(19:00 Hrs) MW	Off Peak(03:00 Hrs) MW	Maximum Interchange (MW)		Energy (MU)		Net Energy MU
			Import	Export	Import	Export	
Vindhychall(HVDC B/B)	-50	-250	0	250	0.00	4.01	-4.01
765 KV Gwalior-Agra (D/C)	2271	2051	2769	0	54.14	0.00	54.14
400 KV Zerda-Kankroli	127	181	261	0	3.70	0.00	3.70
400 KV Zerda-Bhinmal	189	206	305	0	4.49	0.00	4.49
220 KV Auraiya-Malanpur	-56	-48	0	104	0.00	1.04	-1.04
220 KV Badod-Kota/Morak	50	41	88	19	1.21	0.00	1.21
Mundra-Mohindergerah(HVDC Bipole)	1798	1202	1804	0.00	35.70	0.00	35.70
400 KV Vindhychal - Rihand	0	0	0	0	0.00	0.00	0.00
765 kV Phagi-Gwalior (D/C)	1264	1085	1462	0	30.21	0.00	30.21
Sub Total WR	5593	4468			129.45	5.05	124.39
Pusauli Bypass/HVDC	164	-150	150	165	2.07	1.32	0.74
400 KV MZP- GKP (D/C)	131	454	510	0	7.93	0.00	7.93
400 KV Patna-Balia(D/C) X 2	548	563	613	0	12.92	0.00	12.92
400 KV B Sharif-Balia (D/C)	26	148	205	0	2.69	0.00	2.69
765 KV Gaya-Balia	212	298	361	0	6.22	0.00	6.22
765 KV Gaya-Varanasi (D/C)	480	537	716	0	13.06	0.00	13.06
220 KV Pusauli-Sahupuri	164	185	185	0	3.68	0.00	3.68
132 KV K'nasa-Sahupuri	-42	-32	0	50	0.00	0.78	-0.78
132 KV Son Ngr-Rihand	-35	-37	0	40	0.00	0.83	-0.83
132 KV Garhwa-Rihand	0	0	0	0	0.00	0.00	0.00
765 KV Sasaram - Fatehpur	21	-58	136	83	0.38	0.00	0.38
400 KV Barh -GKP (D/C)	468	444	474	0	10.41	0.00	10.41
400 kV B Sharif - Varanasi (D/C)	73	97	192	0	2.67	0.00	2.67
Sub Total ER	2210	2449			62.02	2.94	59.09
+/- 800 KV BiswanathChariali-Agra	964	962	985	0.00	23.21	0.00	23.21
Sub Total NER	964	962			23.21	0.00	23.21
Total IR Exch	8767	7879			214.68	7.99	206.69

VI(B). Inter Regional Schedule & Actual Exchanges [Import (+ve)/Export (-ve)] [Corridor wise]

ISGS/LT Schedule (MU)			Bilateral Schedule (MU)		Power Exchange Shdl (MU)		Wheeling (MU)	
ER	Bhutan	Total	Through ER	Through WR	Through ER	Through WR	Through ER	Through WR
42.87	3.62	46.49	11.86	0.14	11.67	13.24	0.00	0.00

Total IR Schedule (MU)			Total IR Actual (MU)			Net IR UI (MU)		
Through ER	Through WR Inclds Mndra	Total	Through ER(including NER)	Through WR	Total	Through ER (including NER)	Through WR	Total
70.02	132.17	202.19	82.30	124.39	206.69	12.27	-7.77	4.50

VI(C). Inter National Exchange with Nepal [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(19:00 Hrs) MW	Off Peak(03:00 Hrs) MW	Maximum Interchange (MW)		Energy (MU)		Net Energy MU
			Import	Export	Import	Export	
132 KV Tanakpur - Mahendarnagar	-22	0	0	22	0	0	-0.06

VII. Frequency Profile <----- % of Time Frequency ----->

<49.2	<49.7	<49.8	<49.9	<50.0	49.9-50.05	50.05-50.10	50.10-50.20	>50.20	>50.50
0.00	0.00	0.09	7.22	57.07	75.34	15.00	2.49	0.01	0.00

<----- Frequency (Hz) ----->				Average Frequency	Frequency Variation	Std. Dev.	Frequency in 15 Min Block		Freq Dev Index (% of Time)
Maximum		Minimum					MAX	MIN	
Freq	Time	Freq	Time	Hz	Index	(Hz)	(Hz)		
50.20	18.02	49.78	10.10	49.99	0.039	50.20	49.95	24.66	

VIII(A). Voltage profile 400 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)				Voltage Deviat
		Voltage(KV)	Time	Voltage (KV)	Time	<380 kV	<390 kV	>420 kV	>430 kV	
Rihand	400	409	0:18	405	12:42	0.0	0.0	0.0	0.0	0.0
Gorakhpur	400	418	8:02	406	14:16	0.0	0.0	0.0	0.0	0.0
Bareilly(PG)400kV	400	404	0:00	404	0:00	0.0	0.0	0.0	0.0	0.0
Kanpur	400	416	20:52	403	11:40	0.0	0.0	0.0	0.0	0.0
Dadri	400	418	1:56	400	18:32	0.0	0.0	0.0	0.0	0.0
Ballabgarh	400	426	4:02	404	11:40	0.0	0.0	25.4	0.0	25.4
Bawana	400	421	1:03	400	18:31	0.0	0.0	2.2	0.0	2.2
Bassi	400	419	21:51	396	5:50	0.0	0.0	0.0	0.0	0.0
Hissar	400	417	2:39	397	18:33	0.0	0.0	0.0	0.0	0.0
Moga	400	420	1:57	400	18:35	0.0	0.0	0.0	0.0	0.0
Abdullapur	400	427	1:11	403	18:39	0.0	0.0	22.0	0.0	22.0
Nalagarh	400	429	2:46	404	18:46	0.0	0.0	26.5	0.0	26.5
Kishenpur	400	424	3:58	391	18:22	0.0	0.0	11.2	0.0	11.2
Wagoora	400	414	3:22	363	18:23	9.2	35.9	0.0	0.0	9.2
Amritsar	400	428	2:38	404	9:45	0.0	0.0	31.5	0.0	31.5
Kashipur	400	0	0:00	0	0:00	0.0	0.0	0.0	0.0	0.0
Hamirpur	400	0	0:00	0	0:00	100.0	100.0	0.0	0.0	100.0
Rishikesh	400	412	4:06	387	12:11	0.0	9.7	0.0	0.0	0.0

VIII(B). Voltage profile 765 kV

Station	Voltage Level (kV)	Maximum		Minimum		Voltage (in % of Time)				Voltage Deviat
		Voltage(KV)	Time	Voltage (KV)	Time	<728 kV	<742 kV	>800 kV	>820 kV	
Fatehpur	765	777	20:55	752	8:44	0.0	0.0	0.0	0.0	0.0
Balia	765	782	7:04	763	18:41	0.0	0.0	0.0	0.0	0.0
Moga	765	796	1:57	764	18:35	0.0	0.0	0.0	0.0	0.0
Agra	765	789	21:51	754	9:13	0.0	0.0	0.0	0.0	0.0
Bhiwani	765	798	21:47	767	9:43	0.0	0.0	0.0	0.0	0.0
Unnao	765	764	0:00	742	11:49	0.0	0.0	0.0	0.0	0.0
Lucknow	765	785	21:51	762	11:39	0.0	0.0	0.0	0.0	0.0
Meerut	765	800	21:50	763	8:43	0.0	0.0	0.0	0.0	0.0
Jhatikara	765	799	21:49	767	9:43	0.0	0.0	0.0	0.0	0.0
Bareilly 765 kV	765	782	21:48	757	18:39	0.0	0.0	0.0	0.0	0.0
Anta	765	788	21:49	758	9:48	0.0	0.0	0.0	0.0	0.0
Phagi	765	790	20:50	758	9:48	0.0	0.0	0.0	0.0	0.0

Note : '0' in Max / Min Col -> Telemetry Outage

IX. Reservoir Parameters:

Name of Reservoir	Parameters		Present Parameters		Last Year		Last day	
	FRL (m)	MDDL (m)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (m ³ /s)	Usage (m ³ /s)
Bhakra	513.59	445.62	500.68	1127.29	510.20	1560.04	293.45	526.30
Pong	426.72	384.05	415.62	705.67	419.74	875.55	77.53	226.34
Tehri	829.79	740.04	824.20	1091.02	819.65	995.26	110.39	126.00
Koteswar	612.50	598.50	609.53	4.30	610.83	4.95	126.00	119.73
Chamera-I	760.00	748.75	758.47	0.00	0.00	0.00	76.51	59.79
Rihand	268.22	252.98	0.00	0.00	0.00	0.00	0.00	0.00
RPS	352.80	343.81	0.00	0.00	0.00	0.00	0.00	0.00
Jawahar Sagar	298.70	295.78	0.00	0.00	0.00	0.00	0.00	0.00
RSD	527.91	487.91	515.67	3.44	512.84	3.61	77.43	133.94

* NA: Not Available

X(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00 Hrs)			Peak Hours (19:00 Hrs)			Day Energy (MU)		
	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MU)	IEX / PXIL (MU)	Total (MU)
Punjab	0	0	0	0	2	0	0.00	1.79	1.79
Delhi	6	-116	0	13	32	0	1.36	0.76	2.12
Haryana	171	-69	0	322	351	0	6.34	5.31	11.64
HP	105	-22	0	-8	-310	0	2.71	-3.67	-0.97
J&K	61	0	0	61	248	0	2.91	2.03	4.94
CHD	0	0	0	0	0	-26	0.00	0.17	0.17
Rajasthan	-5	575	0	-7	583	0	-0.13	13.87	13.74
UP	177	785	0	115	-100	0	-0.79	2.47	1.68
Uttarakhand	25	133	0	25	132	0	0.46	6.59	7.04
Total	541	1284	0	521	938	-26	12.86	29.30	42.16

X(B). Short-Term Open Access Details:

State	Bilateral (MW)		IEX (MW)		PXIL (MW)	
	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Punjab	0	0	198	0	0	0
Delhi	113	6	263	-209	0	0
Haryana	399	131	404	-323	0	0
HP	194	-8	1	-527	0	0
J&K	210	61	298	-15	0	0
CHD	0	0	0	0	44	-26
Rajasthan	-5	-7	592	564	0	0
UP	229	-292	785	-100	0	0
Uttarakhand	25	13	557	97	0	0

XI. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter - regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(ii)%age of times ATC violated on the inter-regional corridors

WR	1.39%
ER	0.00%
Simultaneous	2.78%

(iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand - Dadri	0.00%
-----------------------	--------------

XII. Zero Crossing Violations

State	No. of violations(Maximum 8 in a day)	Maximum number of continuous blocks without sign change
Punjab	2	22
Haryana	4	14
Rajasthan	0	12
Delhi	1	20
UP	2	7
Uttarakhand	5	44
HP	2	19
J & K	2	13
Chandigarh	3	25

XIII. System Constraints:**XIV. Grid Disturbance / Any Other Significant Event:****XV. Weather Conditions For 17.10.2016 :**
Normal**XVI. Synchronisation of new generating units :****XVII. Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :****XVIII. Tripping of lines in pooling stations :****XIX. Complete generation loss in a generating station :**

Note: Data(regarding drawal,generation, shortage , inter-regional flows and reservoir levels)of the constituents filled in the report are as per last furnished data by the respective state/constituent to NRLDC.